

February 25, 2015

Ms. Jan Finseth, Structa Wire Corporation
1395 North Grandview Hwy
Vancouver, BC, V5N 1N2
Tel: 604-254-9868

Re: Structa Wire Lath Products used with Adhered Veneer Stone

Ms. Finseth:

Structa Wire products approved in ICC-ES Reports indicating equivalence to 2.5 pound per square yard or 3.4 pound per square yard self-furred metal lath (ASTM C-847) are acceptable to be used with the installation of Headwaters Stone Division (Eldorado Stone, Stonecraft and Dutch Quality Stone) adhered veneer stone products.

Regards,

Rick Garagliano



Director of Technical Sales
Headwaters Stone Division
Everett, WA, US 98203
425-890-3474